

Pinetop-Studios - PSS #1

Pool Equipment Leak

12/12/2021 10:41 AM - Sieu Ngo

Status:	Closed - No Further Action	Start date:	12/12/2021
Priority:	High	Due date:	12/15/2021
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Description			
Keep area dry - leslie			
Confirm leak being diverted. - mike			

History

#1 - 12/19/2021 07:40 AM - Sieu Ngo

- Status changed from New to Completed

Mike stated floor now dry - if ANYONE sees water in this room, please be sure and report instead of ignoring.

ABS pipe put under Pool Pump, thus catching the drip and routing to drain .. no lube was put into seal

#2 - 12/19/2021 07:45 AM - Sieu Ngo

- Status changed from Completed to Closed - No Further Action