

Pinetop-Studios - PSS #10

Shower heads - CLR - Clear Blockage

12/21/2021 05:52 AM - Sieu Ngo

Status:	New	Start date:	12/21/2021
Priority:	Med-High	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Description This needs to be done every two yrs - or upon visual inspection. We have extra shower heads - put in replacement, soak the old unit until clean. Most of the heads were done early November ... need a run thru of all units - in particular, rooms were were unable to access previously (such as 122). During cleaning service, any head found to have blockage, leave comments on this ticket.			