

DWEB - All Hotels, misc - PSS #85

Water Heater Replacement - DC

02/02/2026 08:16 PM - Sieu Ngo

Status:	New	Start date:	02/02/2026
Priority:	Medium	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Description			
<ul style="list-style-type: none">• Sun: Brandy shut off water heater (2 water lines, 1 gas line, electrical to heater)• Tues: will have brandy attempt to drain water tank - hook up hose, activate Pressure release valve• Wed: Anthony to confirm all pipes can be moved out of the way - in particular, re-circ pump - which might require a 1/2 quick disconnect. Just be sure and debur before connecting line.• Thu Night: block off corner area in prep for delivery• Friday: Test run, removing old heater. Old heater will need to be pushed outside - need appliance dolly. New dolly should arrive.• Saturday: Installation of the new water heater.			
Those are the suggested steps. As always, when water needs to be turned off, best to do it around 9:30am			
We are getting rid of a ghe100-200 .. replacing with g100-200. Exact serial/model will need to be documented upon arrival. purchased from HD, Jan 31st			

History

#1 - 03/25/2026 12:21 PM - Sieu Ngo

New Unit Ordered, arrived 3/5/26:

Internet # 300308093 Model # G100-200

Serial A372506598, 100 gallons, mfg 09/2025

Old Unit

Model ghe100-200

Serial - complete RIPPED off.. no chance of recover.

Alternative is \$11k- Mfr. Model GHE100SU-200