

DWEB - All Hotels, misc - PSS #97

WATER HEATER FLUSHES

03/28/2026 04:30 PM - Jal Arancon

Status:	New	Start date:	03/28/2026
Priority:	Medium	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Description			
Flushed every "Even Year" - prefer during April and May.			
MH1			
MH2			
MH4 - COMPLETED BY PAUL 3/28/26			
MH5 - COMPLETED BY PAUL 3/28/26			
MH6			
MH7 - COMPLETED BY PAUL 3/28/26			
MH8 - COMPLETED BY PAUL 3/28/26			
MH9			
MH10			
MH11			
KP1			
KP2			
KP3			
KP4			
KP5 - NEW Lowes WH installed 03/26			
KP6			
KP7			
KP8			
WR - COMPLETED BY PAUL 3/28/26			
PSS - 2 Heaters, need to be done same time			
DC Broiler Room -			
DC Restaurant -			
WI B1:			
WI B2: Old Unit Pulled from BI, flushed at Nov 2025 during install, next due: April 2028			
WI B3, Unit 1:			
WI B3, Unit 2:			
W1:			
BI MAIN / NOT ACTIVE			
BI OFFICE / NOT ACTIVE			
NOTE: NEXT FLUSH WILL BE IN 2028 / NEEDS TO BE DONE DURING MONTH OF APRIL AND MAY			

History

#1 - 03/28/2026 04:44 PM - Jal Arancon

- Description updated

#2 - 03/28/2026 04:54 PM - Jal Arancon

- Description updated

#3 - 03/28/2026 05:01 PM - Jal Arancon

- Description updated

#4 - 03/28/2026 09:06 PM - Sieu Ngo

- Description updated

#5 - 03/28/2026 09:09 PM - Sieu Ngo

- Description updated